

FIRE SAFETY CERTIFICATE

Dated:


No.

Certified that the Moon International Public School (name of the building or premises) at Khasra No. 889, Vill - Jarha Khurd (Bhujound) Tehsil - Moth, Distt. - Jhansi (UP) (address) comprised of Basement basement(s) Ground & First (upper floors) owned/occupied by Ram Devi Educational Foundation Trust, Near RTO Office, Shivaji Nagar, Jhansi (U.P.) (name of the Institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on 20/06/2016 (date of inspection) in the presence of Dr. Ashok Kumar Yadav, vice chairman (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy class 1st to 12th with effect from 01/06/2016 for a period of 10 years in accordance with rule and subject to compliance of the conditions.

Issued on 20/6/2016 at Moth by

* Strike out whichever is not applicable.

Signature with Seal :


 प्रभारी अधिकारी
 फायर स्टेशन, मोठ (झाँसी)

Name

~~Dr. Ashok Kumar Yadav~~

Designation :

To
 Moon International Public School
 V. Jarha Khurd (Bhujound)
 Teh. Moth Distt. JHANSI (U.P.)
 (Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to

..... (reasons to be recorded).

फा सं०-निरी०/एफ०एस०ओ०/2009-2016

दिनांक-29-5-16

सेवा में

प्रधानाचार्य

मून इंटरनेशनल पब्लिक स्कूल

मुजोद मोठ


सचिव ग्रह (पुलिस) अनुभाग-08 उ०, प० शासन लखनऊ के पत्र संख्या 24/छ-पु०-08-09

वरिष्ठ-1/04 दिनांक-29-05-09 के सापेक्ष में नेशनल बिल्डिंग कोड के अनुसार

पब्लिक स्कूल मुजोद झांसी का मुख्य अग्नि शमन अधिकारी द्वारा अग्नि शमन सुरक्षा की दृष्टि कोण से निरीक्षण किया गया तो निम्नलिखित अग्नि शमन सुरक्षा व्यवस्था पायी गयी।

- | | | | |
|----|---|------------|-------|
| 1- | डी०सी०पी० फायर एक्स | 5 कि०ग्रा० | 2 अदद |
| 2- | ए०बी०सी० फायर एक्स | 5 कि०ग्रा० | 2 अदद |
| 3- | पानी से भरी बाल्टियाँ | - | 5 अदद |
| 4- | बालू से भरी बाल्टियाँ | - | 2 अदद |
| 5- | पानी की टंकी की क्षमता | लीटर में | अदद |
| 6- | फायर स्टेशन का टेलीफोन न० 101, 2445124, 250343 की पट्टिका | | 1 अदद |
| 7- | शिक्षक स्टाप/कर्मचारियों को अग्नि शमन सम्बन्धी जानकारी दी गई। | | |

अतः मून इंटरनेशनल पब्लिक स्कूल मुजोद झांसी को अग्नि शमन सुरक्षा सम्बन्धी आख्या रिपोर्ट प्रदान की जाती है।


अग्नि शमन अधिकारी
मा० झांसी
मोठ (झांसी)